

0	1	2	3	4	5	6	7	8	9
Stück Zahl	Artikel Bezeichnung			Artikel Beschreibung		Artikel Bezüge			
1				Power Electronic A1000-18A		-7B1			
1				EMV-Filter		-7B2			
1				LCD Display ADR80		-9B2			
1				ADR80 400/230V 8A		-9B4			
4	PKZMO-10			Motorschutzschalter		-2F1, -6F1, -5F1, -7F1			
4	NHI-E-11-PKZO			Normalhilfsschalter					
1	C6/3N			Sicherungsautomaten		-9F1			
15	C6/1N			Sicherungsautomaten		-12F1, -11F1, -10F1, -13F1, -4F1, -8F1			
						-15F1, -15F4, -15F3, -15F5, -14F1			
						-15F6, -17F1, -2F2, -15F2			
4	C13/3N			Sicherungsautomaten		-12F2, -13F2, -10F2, -11F2			
3	Signalleuchte grün			Signalglimmlampe grün		-5H1, -3H1, -6H1			
8	Signalleuchte rot			Signalglimmlampe rot		-5H2, -3H2, -4H1, -6H2, -16H2, -7H1			
						-16H1, -9H1			
7	Sockel 4polig			Sockel für Minitur Relais 4polig					
1	TM16+/R/230Vac			Multifunktion Zeitrelais		-4K3			
5	DILM32-XHI22			Hilfsschalterbaustein					
5	DILM15-10(230V50HZ)			Schütz		-6K3, -2K2, -5K3, -6K2, -5K2			
7	Relais4polig230VAC			Miniatur - Relais 4polig		-7K1, -2K1, -7K2, -5K1, -4K1, -6K1			
						-4K2			
1	DILM9-10(230V50HZ)			Schütz		-9K1			
1	DILM32-XHI02			Hilfsschalterbaustein					
4	R25-40_230			Kleinschütz		-12K1, -11K1, -10K1, -13K1			
1				Schaltschrankventilator		-8M1			
1	WS 1000/1200/300/B/H/T			Wandschrank IP 55		-0N1			
6	DILM12-XSPR240			RC-Löschglied		-5N1, -9N1, -6N2, -6N1, -5N2, -2N1			
5				Dixell XR170C 12Vac/dc		-14N1, -13N1, -10N1, -12N1, -11N1			
1				Dixell XJA50D		-16N1			
1				Thermostat		-8P1			
1	LT80 -54,1A AC23			Hauptschalter		-1Q1			
7	M10HEA1			Ausschalter 1pol. 0-1		-4S1, -14S1, -11S1, -10S1, -12S1, -13S1			
						-2S1			
5				Dixell Trafo 230Vac 12Vac		-10T1, -14T1, -13T1, -12T1, -11T1			

				Datum	01.07.14
				Bearb.	Hattinger F.
				Gepr.	
Zust.	Änderung	Datum	Name	Norm	



Gewerbekälte
Silo Lemböckgasse 61

Materialliste

Zeichn.Nr.:
195/14
Blatt 1
von 2 Bl.

